

FX LUMINAIRE STAINLESS STEEL
POTENZA X TRANSFORMER.
SEE LIGHTING PLAN FOR WATTAGE, SIZE
AND SWITCHING TYPE.

MOUNT BEHIND PLANT MATERIAL OR
BOULDERS TO OBSCURE A DIRECT VIEW
OF THE POWERX TRANSFORMER.
LOCATE AWAY FROM IRRIGATION HEADS.


GFI PROTECTED 120V POWER WITH
WATERPROOF QUTLET COVER

ALL METAL PARTS MUST BE GROUNDED
IN ACCORDANCE TO NEC GUIDELINES.

BOTTOM OF TRANSFORMER CABINET TO
BE A MINIMUM OF 12" ABOVE FINISHED
GRADE.

RUN LOW VOLTAGE CABLES IN 1.50"
GRAY PVC CONDUIT UNTIL THEY ARE
12" BELOW FINISHED GRADE.

FINISHED GRADE



UNIT HUMS DO NOT MOUNT ON
BEDROOM WALLS

SECTION/ELEVATION

XX PONTENZA X TRANSFORMER
POST MOUNT

NOT TO SCALE

FX LUMINAIRE DETAIL